

PLATEAU ELECTRIC COOPERATIVE

POLICY NO. B4

SUBJECT: LOCAL WIRING REQUIREMENTS

POLICY:

Plateau Electric requires the following in addition to all other National Electric Code requirements:

- A. All risers shall be installed a minimum of 12 feet from the ground.
- B. All risers passing through and above roofs shall be installed a minimum of 36 inches above roof in 2-inch rigid metal conduit.
- C. The meter base shall be installed a minimum of 5 feet 6 inches above ground and not over 6 feet.
- D. No services shall be attached to trees.
- E. No new 2 wire services will be allowed.
- F. If multiple conduits are to be attached to a pole, stand-off brackets will be required.
- G. If conduits are to be attached to Plateau Electric poles with 600 volts or greater, then the consumer / electrician may request assistance which must be scheduled through the Plateau Electric office where the work shall be performed. The consumer / electrician shall be required to be present at the job location.